

CUMHURİYET WTP SLUDGE MASS I

Qdes= 720,300

FROM FILTER B/W

W,kg/d =	1,000
Q, m3/d=	16000.0
% DS =	0.006%
Dens, kg/m	1000

FROM FILTER PESS

W,kg/d =	9,025
Q, m3/d=	2348.8
% DS =	0.384%
Dens, kg/m	1000

FROM THICKENER

W,kg/d =	4,750
Q, m3/d=	3,755
% DS =	0.12651%
Dens, kg/m	1000



RETURN

W,kg/d =	14,775
Q, m3/d=	742,404
% DS =	0.002%
Dens, kg/m3	1000

INPUT

Q, m3/d=

W,kg/d =	100,000
Q, m3/d=	742,670
% DS =	0.013%
Dens, kg/m3	1000



Solids capt. Eff=

	90%
W,kg/d =	81,225

Q, m ³ /d=	229.8
% DS =	35.00%
Dens, kg/m	1010

BALANCE

???

2.17%

